

# BUILDING REGULATIONS ADVISORY COMMITTEE

## Certificate of Accreditation

### ULTRATEX GREY BOARD EIFS WALL CLADDING SYSTEMS

Ultratex Wall Cladding & Coating Pty. Ltd.  
Factory 4/11 Malcolm Court  
KEALBA VIC 3021

has applied to the Building Regulations Advisory Committee for the accreditation of the **Ultratex Grey Board EIFS Wall Cladding Systems**, as suitable for use as a wall cladding system.

The Building Regulations Advisory Committee appointed under Division 4 of Part 12 of the *Building Act 1993* has examined the application and accredited the **Ultratex Grey Board EIFS Wall Cladding Systems** as complying with Performance Requirements:

**P2.1.1 of Volume Two of the National Construction Code Series**  
**P2.2.2 of Volume Two of the National Construction Code Series**  
**Building Code of Australia Class 1 and Class 10 Buildings,**

as adopted by the *Building Regulations 2006*, as these clauses apply within the State of Victoria to wall cladding, subject to the following conditions:


1. This accreditation applies to the Ultratex Grey Board EIFS direct fix and cavity wall cladding systems only.
2. This product must be installed on Class 1 and 10 buildings only.
3. This product must be installed in wind classifications N1 to N4 only.
4. This product must be installed in accordance with the Ultratex Grey Board EIFS Wall Cladding Systems Installation & Technical Manual version 2D dated 02 December 2014.
5. This product must be installed on timber framework only with minimum 90mm x 35mm studs at a maximum spacing of 600mm and fastener spacing of 300mm.
6. This product must be installed with breathable sarking.
7. Fasteners must be installed through polystyrene panels with a minimum of 25mm depth into timber framework.
8. All fixtures and features attached to the wall must be secured into the wall framing.
9. This product must be installed a minimum of 100mm from any external ground surface.
10. Render must be applied strictly in accordance with manufacturer's installation requirements.

Date issued:

12 March 2015

Certificate Number:

V15/01



Jarrod Edwards

Secretary - Building Regulations Advisory Committee